

Session C Results: Regulator Vent Guidelines

Proposed Revisions for VGOA
Discussion

Proposals for VGOA Discussion

- Openings to Buildings 3' Horizontal Rule
 - Revise the 3' horizontal distance requirement to a 3' radial distance
 - Revise “...shall not be installed underneath any openings located on the first floor...” to a minimum of 1' of horizontal distance combined with the 3' radial distance
 - Allow the use of Pietro Fiorentini or equivalent ventless/limited release regulators without any required spacing limitations, however minimum spacing requirements should be followed when possible

Proposals for VGOA Discussion

- Rotating Electrical Equipment
 - Revise from the 3' horizontal distance to a 3' radial distance
 - Revise language to measure the distance from the closest edge of the electrical equipment, i.e. fan or other motor, relay panel, breaker panel, etc.
 - Allow the use of Pietro Fiorentini or equivalent ventless/limited release regulators without any required spacing limitations, however minimum spacing requirements should be followed when possible